



Element  
Suite 100, 328 Ley Road  
Fort Wayne, Indiana  
46825, United States

T: +1 (260) 471-7000  
F: +1  
E: Info.FortWayne@element.com  
W: www.element.com

January 6, 2023

Aija Putelis  
120 Water Audit  
PO Box 604  
ZIONSVILLE, IN 46077

RE: 1966: Floyds Knob Elementary

Dear Aija Putelis:

Lot Id: 135364

Element Materials Technology – Fort Wayne received 143 sample(s) on 12/21/2022 for the analyses presented in the following report.

In accordance with your instructions, a laboratory of Element Materials Technology Fort Wayne LLC either conducted or subcontracted these analyses. Subcontracted analyses will be identified in an accompanying case narrative and any associated report(s) will be attached in full. Unless otherwise noted in the case narrative, all analyses were conducted using approved methodologies. Reported results relate only to the items tested.

Estimated uncertainty is available upon request. This report shall not be reproduced, except in full, without the written approval of the laboratory.

If you have any questions regarding these test results, please feel free to call.

Sincerely,

A handwritten signature in black ink that reads 'Megan Krauskopf'.

Megan Krauskopf  
Project Manager  
Suite 100, 328 Ley Road,  
Fort Wayne, IN 46825

**Accreditation**

TNI:2016 (Florida)  
ISO 17025:2017 (A2LA)  
Indiana  
Michigan  
South Dakota  
Tennessee

**Cert #**

E871168  
6190.02  
M-02-05  
9030  
--  
04911

## Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

<b>Reference Number</b>	135364-1	<b>Sample Date</b>	2022-12-17 08:30			
<b>Sample Description</b>	101 Initial	<b>Sample Matrix</b>	Drinking Water			
<b>Analyte</b>	<b>Result</b>	<b>Units</b>	<b>DF</b>	<b>Nominal DL</b>	<b>Analysis Start Date/Time</b>	<b>Analyst Initials</b>
<b>Metals - Total in Water by ICP-MS</b>						
Lead	Total	0.8	µg/L	1	0.2	Jan 05, 2023 05:23 FR

<b>Reference Number</b>	135364-2	<b>Sample Date</b>	2022-12-17 08:30			
<b>Sample Description</b>	102 Initial	<b>Sample Matrix</b>	Drinking Water			
<b>Analyte</b>	<b>Result</b>	<b>Units</b>	<b>DF</b>	<b>Nominal DL</b>	<b>Analysis Start Date/Time</b>	<b>Analyst Initials</b>
<b>Metals - Total in Water by ICP-MS</b>						
Lead	Total	0.2	µg/L	1	0.2	Jan 05, 2023 05:23 FR

<b>Reference Number</b>	135364-3	<b>Sample Date</b>	2022-12-17 08:32			
<b>Sample Description</b>	102 Flush	<b>Sample Matrix</b>	Drinking Water			
<b>Analyte</b>	<b>Result</b>	<b>Units</b>	<b>DF</b>	<b>Nominal DL</b>	<b>Analysis Start Date/Time</b>	<b>Analyst Initials</b>
<b>Metals - Total in Water by ICP-MS</b>						
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23 FR

<b>Reference Number</b>	135364-4	<b>Sample Date</b>	2022-12-17 08:33			
<b>Sample Description</b>	103 Initial	<b>Sample Matrix</b>	Drinking Water			
<b>Analyte</b>	<b>Result</b>	<b>Units</b>	<b>DF</b>	<b>Nominal DL</b>	<b>Analysis Start Date/Time</b>	<b>Analyst Initials</b>
<b>Metals - Total in Water by ICP-MS</b>						
Lead	Total	0.9	µg/L	1	0.2	Jan 05, 2023 05:23 FR

<b>Reference Number</b>	135364-5	<b>Sample Date</b>	2022-12-17 08:34			
<b>Sample Description</b>	104 Initial	<b>Sample Matrix</b>	Drinking Water			
<b>Analyte</b>	<b>Result</b>	<b>Units</b>	<b>DF</b>	<b>Nominal DL</b>	<b>Analysis Start Date/Time</b>	<b>Analyst Initials</b>
<b>Metals - Total in Water by ICP-MS</b>						
Lead	Total	0.5	µg/L	1	0.2	Jan 05, 2023 05:23 FR

<b>Reference Number</b>	135364-6	<b>Sample Date</b>	2022-12-17 08:34			
<b>Sample Description</b>	104 Flush	<b>Sample Matrix</b>	Drinking Water			
<b>Analyte</b>	<b>Result</b>	<b>Units</b>	<b>DF</b>	<b>Nominal DL</b>	<b>Analysis Start Date/Time</b>	<b>Analyst Initials</b>
<b>Metals - Total in Water by ICP-MS</b>						
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23 FR

**Analytical Report**

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix	Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
135364-7	105 Initial	2022-12-17 08:35	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	1.3	µg/L	1	0.2	Jan 05, 2023 05:23	FR
135364-8	106 Initial	2022-12-17 08:35	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23	FR
135364-9	106 Flush	2022-12-17 08:36	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23	FR
135364-10	107 Initial	2022-12-17 08:37	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23	FR
135364-11	107 Flush	2022-12-17 08:38	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23	FR
135364-12	108 Initial	2022-12-17 08:39	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	0.6	µg/L	1	0.2	Jan 05, 2023 05:23	FR

**Analytical Report**

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-13	109 Initial	2022-12-17 08:39	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2		Jan 05, 2023 05:23	FR
135364-14	109 Flush	2022-12-17 08:40	Drinking Water					
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2		Jan 05, 2023 05:23	FR
135364-15	110 Initial	2022-12-17 08:41	Drinking Water					
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	13.8	µg/L	1	0.2		Jan 05, 2023 05:23	FR
135364-16	111 Initial	2022-12-17 08:41	Drinking Water					
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	1.3	µg/L	1	0.2		Jan 05, 2023 05:23	FR
135364-17	111 Flush	2022-12-17 08:43	Drinking Water					
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.3	µg/L	1	0.2		Jan 05, 2023 05:23	FR
135364-18	112 Initial	2022-12-17 08:44	Drinking Water					
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	7.6	µg/L	1	0.2		Jan 05, 2023 05:23	FR

## Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-19	113 Initial	2022-12-17 08:44	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.8	µg/L	1	0.2		Jan 05, 2023 05:23	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-20	113 Flush	2022-12-17 08:46	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.9	µg/L	1	0.2		Jan 05, 2023 05:23	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-21	114 Initial	2022-12-17 08:47	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.9	µg/L	1	0.2		Jan 05, 2023 05:23	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-22	115 Initial	2022-12-17 08:47	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.8	µg/L	1	0.2		Jan 05, 2023 05:23	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-23	115 Flush	2022-12-17 08:48	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.3	µg/L	1	0.2		Jan 05, 2023 05:23	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-24	116 Initial	2022-12-17 08:49	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.4	µg/L	1	0.2		Jan 05, 2023 05:23	FR

## Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-25	117 Initial	2022-12-17 08:49	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.8	µg/L	1	0.2		Jan 05, 2023 05:23	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-26	117 Flush	2022-12-17 08:51	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2		Jan 05, 2023 05:23	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-27	118 Initial	2022-12-17 08:52	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2		Jan 05, 2023 05:23	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-28	119 Initial	2022-12-17 08:52	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.2	µg/L	1	0.2		Jan 05, 2023 05:23	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-29	120 Initial	2022-12-17 08:53	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.3	µg/L	1	0.2		Jan 05, 2023 05:23	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-30	121 Initial	2022-12-17 08:54	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.3	µg/L	1	0.2		Jan 05, 2023 05:23	FR

**Analytical Report**

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-31	122 Initial	2022-12-17 08:55	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
135364-32	123 Initial	2022-12-17 08:56	Drinking Water					
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
135364-33	124 Initial	2022-12-17 08:57	Drinking Water					
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
135364-34	124 Flush	2022-12-17 08:58	Drinking Water					
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
135364-35	125 Initial	2022-12-17 08:59	Drinking Water					
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	1.5	µg/L	1	0.2	Jan 05, 2023 05:23		FR
135364-36	125 Flush	2022-12-17 09:00	Drinking Water					
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.6	µg/L	1	0.2	Jan 05, 2023 05:23		FR

## Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix	Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
135364-37	126 Initial	2022-12-17 09:01	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	0.4	µg/L	1	0.2	Jan 05, 2023 05:23	FR
135364-38	127 Initial	2022-12-17 09:01	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	0.5	µg/L	1	0.2	Jan 05, 2023 05:23	FR
135364-39	128 Initial	2022-12-17 09:02	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	0.4	µg/L	1	0.2	Jan 05, 2023 05:23	FR
135364-40	128 Flush	2022-12-17 09:03	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	1.5	µg/L	1	0.2	Jan 05, 2023 05:23	FR
135364-41	129 Initial	2022-12-17 09:03	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	3.1	µg/L	1	0.2	Jan 05, 2023 05:23	FR
135364-42	130 Initial	2022-12-17 09:04	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	1.1	µg/L	1	0.2	Jan 05, 2023 05:23	FR



## Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-43	131 Initial	2022-12-17 09:04	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.9	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-44	131 Flush	2022-12-17 09:05	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-45	132 Initial	2022-12-17 09:05	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-46	132 Flush	2022-12-17 09:06	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-47	133 Initial	2022-12-17 09:10	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.3	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-48	133 Flush	2022-12-17 09:10	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR

## Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-49	134 Initial	2022-12-17 09:12	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.5	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-50	134 Flush	2022-12-17 09:13	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-51	135 Initial	2022-12-17 09:14	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.3	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-52	135a Initial	2022-12-17 09:15	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-53	135a Flush	2022-12-17 09:16	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-54	136 Initial	2022-12-17 09:16	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.3	µg/L	1	0.2	Jan 05, 2023 05:23		FR

**Analytical Report**

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-55	136 Flush	2022-12-17 09:17	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-56	137 Initial	2022-12-17 09:18	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-57	137 Flush	2022-12-17 09:19	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-58	138 Initial	2022-12-17 09:20	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.4	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-59	138 Flush	2022-12-17 09:20	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-60	139 Initial	2022-12-17 09:22	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.4	µg/L	1	0.2	Jan 05, 2023 05:23		FR

## Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

<b>Reference Number</b> 135364-61	<b>Sample Date</b> 2022-12-17 09:23
<b>Sample Description</b> 139 Flush	<b>Sample Matrix</b> Drinking Water

Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>						
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23 FR

<b>Reference Number</b> 135364-62	<b>Sample Date</b> 2022-12-17 09:24
<b>Sample Description</b> 140 Initial	<b>Sample Matrix</b> Drinking Water

Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>						
Lead	Total	0.2	µg/L	1	0.2	Jan 05, 2023 05:23 FR

<b>Reference Number</b> 135364-63	<b>Sample Date</b> 2022-12-17 09:24
<b>Sample Description</b> 141 Initial	<b>Sample Matrix</b> Drinking Water

Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>						
Lead	Total	0.6	µg/L	1	0.2	Jan 05, 2023 05:23 FR

<b>Reference Number</b> 135364-64	<b>Sample Date</b> 2022-12-17 09:25
<b>Sample Description</b> 142 Initial	<b>Sample Matrix</b> Drinking Water

Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>						
Lead	Total	0.5	µg/L	1	0.2	Jan 05, 2023 05:23 FR

<b>Reference Number</b> 135364-65	<b>Sample Date</b> 2022-12-17 09:26
<b>Sample Description</b> 143 Initial	<b>Sample Matrix</b> Drinking Water

Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>						
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23 FR

<b>Reference Number</b> 135364-66	<b>Sample Date</b> 2022-12-17 09:27
<b>Sample Description</b> 144 Initial	<b>Sample Matrix</b> Drinking Water

Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>						
Lead	Total	0.2	µg/L	1	0.2	Jan 05, 2023 05:23 FR

**Analytical Report**

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix	Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
135364-67	145 Initial	2022-12-17 09:27	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>							
	Total			Lead	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23	FR	
135364-68	146 Initial	2022-12-17 09:28	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>							
	Total			Lead	0.3	µg/L	1	0.2	Jan 05, 2023 05:23	FR	
135364-69	147 Initial	2022-12-17 09:29	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>							
	Total			Lead	0.8	µg/L	1	0.2	Jan 05, 2023 05:23	FR	
135364-70	147 Flush	2022-12-17 09:29	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>							
	Total			Lead	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23	FR	
135364-71	148 Initial	2022-12-17 09:31	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>							
	Total			Lead	0.3	µg/L	1	0.2	Jan 05, 2023 05:23	FR	
135364-72	148 Flush	2022-12-17 09:31	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>							
	Total			Lead	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23	FR	

**Analytical Report**

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-73	149 Initial	2022-12-17 09:33	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.3	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-74	149 Flush	2022-12-17 09:34	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-75	150 Initial	2022-12-17 09:39	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.9	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-76	150 Flush	2022-12-17 09:39	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-77	151 Initial	2022-12-17 09:41	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	1.3	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-78	151 Flush	2022-12-17 09:42	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR

## Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-79	152 Initial	2022-12-17 09:42	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-80	152 Flush	2022-12-17 09:43	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	1.4	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-81	153 Initial	2022-12-17 09:44	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.4	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-82	154 Initial	2022-12-17 09:45	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	1.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-83	154 Flush	2022-12-17 09:46	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-84	155 Initial	2022-12-17 09:47	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.5	µg/L	1	0.2	Jan 05, 2023 05:23		FR

## Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

<b>Reference Number</b>	135364-85	<b>Sample Date</b>	2022-12-17 09:50			
<b>Sample Description</b>	157 Initial	<b>Sample Matrix</b>	Drinking Water			
<b>Analyte</b>	<b>Result</b>	<b>Units</b>	<b>DF</b>	<b>Nominal DL</b>	<b>Analysis Start Date/Time</b>	<b>Analyst Initials</b>
<b>Metals - Total in Water by ICP-MS</b>						
Lead	Total	0.3	µg/L	1	0.2	Jan 05, 2023 05:23 FR

<b>Reference Number</b>	135364-86	<b>Sample Date</b>	2022-12-17 09:50			
<b>Sample Description</b>	157 Flush	<b>Sample Matrix</b>	Drinking Water			
<b>Analyte</b>	<b>Result</b>	<b>Units</b>	<b>DF</b>	<b>Nominal DL</b>	<b>Analysis Start Date/Time</b>	<b>Analyst Initials</b>
<b>Metals - Total in Water by ICP-MS</b>						
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23 FR

<b>Reference Number</b>	135364-87	<b>Sample Date</b>	2022-12-17 09:51			
<b>Sample Description</b>	158 Initial	<b>Sample Matrix</b>	Drinking Water			
<b>Analyte</b>	<b>Result</b>	<b>Units</b>	<b>DF</b>	<b>Nominal DL</b>	<b>Analysis Start Date/Time</b>	<b>Analyst Initials</b>
<b>Metals - Total in Water by ICP-MS</b>						
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23 FR

<b>Reference Number</b>	135364-88	<b>Sample Date</b>	2022-12-17 09:52			
<b>Sample Description</b>	158 Flush	<b>Sample Matrix</b>	Drinking Water			
<b>Analyte</b>	<b>Result</b>	<b>Units</b>	<b>DF</b>	<b>Nominal DL</b>	<b>Analysis Start Date/Time</b>	<b>Analyst Initials</b>
<b>Metals - Total in Water by ICP-MS</b>						
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23 FR

<b>Reference Number</b>	135364-89	<b>Sample Date</b>	2022-12-17 09:54			
<b>Sample Description</b>	159 Initial	<b>Sample Matrix</b>	Drinking Water			
<b>Analyte</b>	<b>Result</b>	<b>Units</b>	<b>DF</b>	<b>Nominal DL</b>	<b>Analysis Start Date/Time</b>	<b>Analyst Initials</b>
<b>Metals - Total in Water by ICP-MS</b>						
Lead	Total	5.2	µg/L	1	0.2	Jan 05, 2023 05:23 FR

<b>Reference Number</b>	135364-90	<b>Sample Date</b>	2022-12-17 09:55			
<b>Sample Description</b>	159 Flush	<b>Sample Matrix</b>	Drinking Water			
<b>Analyte</b>	<b>Result</b>	<b>Units</b>	<b>DF</b>	<b>Nominal DL</b>	<b>Analysis Start Date/Time</b>	<b>Analyst Initials</b>
<b>Metals - Total in Water by ICP-MS</b>						
Lead	Total	1.8	µg/L	1	0.2	Jan 05, 2023 05:23 FR



**Analytical Report**

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-91	160 Initial	2022-12-17 09:56	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.8	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-92	160a Initial	2022-12-17 09:57	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.3	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-93	160b Initial	2022-12-17 09:57	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.5	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-94	161 Initial	2022-12-17 09:58	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.6	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-95	161a Initial	2022-12-17 09:58	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.3	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-96	161b Initial	2022-12-17 09:59	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.6	µg/L	1	0.2	Jan 05, 2023 05:23		FR

## Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-97	162 Initial	2022-12-17 10:00	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-98	162a Initial	2022-12-17 10:01	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-99	162a Flush	2022-12-17 10:01	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-100	163 Initial	2022-12-17 10:03	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	1.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-101	163 Flush	2022-12-17 10:03	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-102	164 Initial	2022-12-17 10:04	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.4	µg/L	1	0.2	Jan 05, 2023 05:23		FR

## Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix	Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
135364-103	165 Initial	2022-12-17 10:05	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23	FR
135364-104	166 Initial	2022-12-17 10:07	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23	FR
135364-105	166 Flush	2022-12-17 10:08	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23	FR
135364-106	167 Initial	2022-12-17 10:09	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	0.9	µg/L	1	0.2	Jan 05, 2023 05:23	FR
135364-107	167 Flush	2022-12-17 10:10	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23	FR
135364-108	168 Initial	2022-12-17 10:13	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23	FR

## Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-109	168 Flush	2022-12-17 10:14	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
135364-110	169 Initial	2022-12-17 10:15	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.5	µg/L	1	0.2	Jan 05, 2023 05:23		FR
135364-111	169 Flush	2022-12-17 10:16	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
135364-112	170 Initial	2022-12-17 10:17	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.4	µg/L	1	0.2	Jan 05, 2023 05:23		FR
135364-113	170 Flush	2022-12-17 10:17	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
135364-114	171 Initial	2022-12-17 10:19	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.3	µg/L	1	0.2	Jan 05, 2023 05:23		FR

## Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-115	171 Flush	2022-12-17 10:20	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-116	172 Initial	2022-12-17 10:21	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.3	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-117	172 Flush	2022-12-17 10:22	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-118	173 Initial	2022-12-17 10:22	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.5	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-119	173 Flush	2022-12-17 10:23	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:23		FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-120	174 Initial	2022-12-17 10:34	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	1.6	µg/L	1	0.2	Jan 05, 2023 05:23		FR

**Analytical Report**

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
135364-121	174 Flush	2022-12-17 10:35	Drinking Water					
Analyte	Result	Units	DF	Nominal DL				
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.2	µg/L	1	0.2	Jan 05, 2023 05:24	FR	
135364-122	175 Initial	2022-12-17 10:37	Drinking Water					
Analyte	Result	Units	DF	Nominal DL				
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.6	µg/L	1	0.2	Jan 05, 2023 05:24	FR	
135364-123	175 Flush	2022-12-17 10:38	Drinking Water					
Analyte	Result	Units	DF	Nominal DL				
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	1.8	µg/L	1	0.2	Jan 05, 2023 05:24	FR	
135364-124	176 Initial	2022-12-17 10:39	Drinking Water					
Analyte	Result	Units	DF	Nominal DL				
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.6	µg/L	1	0.2	Jan 05, 2023 05:24	FR	
135364-125	176 Flush	2022-12-17 10:40	Drinking Water					
Analyte	Result	Units	DF	Nominal DL				
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	0.5	µg/L	1	0.2	Jan 05, 2023 05:24	FR	
135364-126	177 Initial	2022-12-17 10:41	Drinking Water					
Analyte	Result	Units	DF	Nominal DL				
<b>Metals - Total in Water by ICP-MS</b>								
Lead	Total	<0.2	µg/L	1	0.2	Jan 05, 2023 05:24	FR	

**Analytical Report**

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix	Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
135364-127	178 Initial	2022-12-17 10:41	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>							
	Total			Lead	0.2	µg/L	1	0.2	Jan 05, 2023 05:24	FR	
135364-128	179 Initial	2022-12-17 10:42	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>							
	Total			Lead	0.5	µg/L	1	0.2	Jan 05, 2023 05:24	FR	
135364-129	179a Initial	2022-12-17 10:43	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>							
	Total			Lead	0.4	µg/L	1	0.2	Jan 05, 2023 05:24	FR	
135364-130	179b Initial	2022-12-17 10:43	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>							
	Total			Lead	0.3	µg/L	1	0.2	Jan 05, 2023 05:24	FR	
135364-131	180 Initial	2022-12-17 10:44	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>							
	Total			Lead	<0.2	µg/L	1	0.2	Jan 05, 2023 05:24	FR	
135364-132	181 Initial	2022-12-17 10:44	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>							
	Total			Lead	0.5	µg/L	1	0.2	Jan 05, 2023 05:24	FR	

## Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix	Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
135364-133	181a Initial	2022-12-17 10:45	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	0.3	µg/L	1	0.2	Jan 05, 2023 05:24	FR
135364-134	181b Initial	2022-12-17 10:45	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	0.2	µg/L	1	0.2	Jan 05, 2023 05:24	FR
135364-135	181c Initial	2022-12-17 10:46	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	0.2	µg/L	1	0.2	Jan 05, 2023 05:24	FR
135364-136	182 Initial	2022-12-17 10:47	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	<0.2	µg/L	1	0.2	Jan 05, 2023 05:24	FR
135364-137	182 Flush	2022-12-17 10:47	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	<0.2	µg/L	1	0.2	Jan 05, 2023 05:24	FR
135364-138	183 Initial	2022-12-17 10:49	Drinking Water	<b>Metals - Total in Water by ICP-MS</b>						
	Total			Lead	0.7	µg/L	1	0.2	Jan 05, 2023 05:24	FR



## Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

Reference Number	Sample Date	Sample Description	Sample Matrix	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
135364-139	2022-12-17 10:50	183 Flush	Drinking Water					
<b>Analyte</b>								
<b>Metals - Total in Water by ICP-MS</b>								
Lead		Total		0.2	1	0.2	Jan 05, 2023 05:24	FR
<b>Analyte</b>								
<b>Metals - Total in Water by ICP-MS</b>								
Lead		Total		1.9	1	0.2	Jan 05, 2023 05:24	FR
<b>Analyte</b>								
<b>Metals - Total in Water by ICP-MS</b>								
Lead		Total		0.5	1	0.2	Jan 05, 2023 05:24	FR
<b>Analyte</b>								
<b>Metals - Total in Water by ICP-MS</b>								
Lead		Total		0.5	1	0.2	Jan 05, 2023 05:24	FR
<b>Analyte</b>								
<b>Metals - Total in Water by ICP-MS</b>								
Lead		Total		<0.2	1	0.2	Jan 05, 2023 05:24	FR

Approved by:   
Megan Krauskopf  
Project Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

### Methodology and Notes

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1966: Floyds Knob Elementary	Lot ID: <b>135364</b>
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Dec 21, 2022
Company:	LSD:	Date Reported: Jan 6, 2023
	P.O.: IFA_LIF_2019	Report Number: 236077
	Proj. Acct. code:	

### Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Metals ICP-MS Total in water	EPA	Trace Elements in Waters and Wastes by Inductively Coupled Plasma-Mass Spectrometry, E200.8	Jan 5, 2023	Fort Wayne
Metals ICP-MS Total in water	EPA	Trace Elements in Waters and Wastes by Inductively Coupled Plasma-Mass Spectrometry, E200.8	Jan 5, 2023	Fort Wayne

### References

EPA United States Environmental Protection Agency

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.