



Element
Suite 100, 328 Ley Road
Fort Wayne, Indiana
46825, United States

T: +1 (260) 471-7000
F: +1
E: Info.FortWayne@element.com
W: www.element.com

December 9, 2022

Aija Putelis
120 Water Audit
PO Box 604
ZIONSVILLE, IN 46077

RE: 1943: Slate Run Elementary School

Dear Aija Putelis:

Lot Id: 132629

Element Materials Technology – Fort Wayne received 123 sample(s) on 11/23/2022 for the analyses presented in the following report.

In accordance with your instructions, a laboratory of Element Materials Technology Fort Wayne LLC either conducted or subcontracted these analyses. Subcontracted analyses will be identified in an accompanying case narrative and any associated report(s) will be attached in full. Unless otherwise noted in the case narrative, all analyses were conducted using approved methodologies. Reported results relate only to the items tested.

Estimated uncertainty is available upon request. This report shall not be reproduced, except in full, without the written approval of the laboratory.

If you have any questions regarding these test results, please feel free to call.

Sincerely,

A handwritten signature in black ink that reads 'Megan Krauskopf'.

Megan Krauskopf
Project Manager
Suite 100, 328 Ley Road,
Fort Wayne, IN 46825

Accreditation

TNI:2016 (Florida)
ISO 17025:2017 (A2LA)
Indiana
Michigan
South Dakota
Tennessee

Cert #

E871168
6190.02
M-02-05
9030
--
04911

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	132629-1	Sample Date	2022-11-19 09:47				
Sample Description	101 Initial	Sample Matrix	Drinking Water				
Analyte		Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR

Reference Number	132629-2	Sample Date	2022-11-19 09:47				
Sample Description	101 Flush	Sample Matrix	Drinking Water				
Analyte		Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR

Reference Number	132629-3	Sample Date	2022-11-19 09:48				
Sample Description	102 Initial	Sample Matrix	Drinking Water				
Analyte		Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR

Reference Number	132629-4	Sample Date	2022-11-19 09:49				
Sample Description	103 Initial	Sample Matrix	Drinking Water				
Analyte		Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR

Reference Number	132629-5	Sample Date	2022-11-19 09:51				
Sample Description	104 Initial	Sample Matrix	Drinking Water				
Analyte		Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	0.4	µg/L	1	0.2	Dec 07, 2022 12:06	FR

Reference Number	132629-6	Sample Date	2022-11-19 09:52				
Sample Description	104 Flush	Sample Matrix	Drinking Water				
Analyte		Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix	Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
132629-7	105 Initial	2022-11-19 09:53	Drinking Water	Metals - Total in Water by ICP-MS						
	Total			Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR
132629-8	106 Initial	2022-11-19 09:54	Drinking Water	Metals - Total in Water by ICP-MS						
	Total			Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR
132629-9	107 Initial	2022-11-19 09:55	Drinking Water	Metals - Total in Water by ICP-MS						
	Total			Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR
132629-10	107 Flush	2022-11-19 09:56	Drinking Water	Metals - Total in Water by ICP-MS						
	Total			Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR
132629-11	108 Initial	2022-11-19 09:56	Drinking Water	Metals - Total in Water by ICP-MS						
	Total			Lead	0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR
132629-12	108 Flush	2022-11-19 09:57	Drinking Water	Metals - Total in Water by ICP-MS						
	Total			Lead	0.5	µg/L	1	0.2	Dec 07, 2022 12:06	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-13	109 Initial	2022-11-19 10:00	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR
<hr/>								
132629-14	110 Initial	2022-11-19 10:02	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	0.3	µg/L	1	0.2		Dec 07, 2022 12:06	FR
<hr/>								
132629-15	111 Initial	2022-11-19 10:03	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	1.1	µg/L	1	0.2		Dec 07, 2022 12:06	FR
<hr/>								
132629-16	112 Initial	2022-11-19 10:04	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR
<hr/>								
132629-17	113 Initial	2022-11-19 10:06	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR
<hr/>								
132629-18	114 Initial	2022-11-19 10:07	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	0.3	µg/L	1	0.2		Dec 07, 2022 12:06	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-19	115 Initial	2022-11-19 10:10	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-20	115 Flush	2022-11-19 10:11	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-21	116 Initial	2022-11-19 10:16	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-22	117 Initial	2022-11-19 10:16	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-23	118 Initial	2022-11-19 10:17	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-24	119 Initial	2022-11-19 10:18	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	132629-25	Sample Date	2022-11-19 10:19			
Sample Description	120 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06 FR

Reference Number	132629-26	Sample Date	2022-11-19 10:21			
Sample Description	121 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06 FR

Reference Number	132629-27	Sample Date	2022-11-19 10:21			
Sample Description	121 Flush	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06 FR

Reference Number	132629-28	Sample Date	2022-11-19 10:22			
Sample Description	122 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06 FR

Reference Number	132629-29	Sample Date	2022-11-19 10:23			
Sample Description	123 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06 FR

Reference Number	132629-30	Sample Date	2022-11-19 10:24			
Sample Description	124 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06 FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-31	124 Flush	2022-11-19 10:26	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR
132629-32	125 Initial	2022-11-19 10:28	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	1.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR
132629-33	126 Initial	2022-11-19 11:17	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR
132629-34	126 Flush	2022-11-19 11:18	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR
132629-35	127 Initial	2022-11-19 11:19	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR
132629-36	127 Flush	2022-11-19 11:20	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-37	128 Initial	2022-11-19 11:21	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-38	128 Flush	2022-11-19 11:22	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-39	129 Initial	2022-11-19 11:23	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-40	129 Flush	2022-11-19 11:23	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-41	130 Initial	2022-11-19 11:24	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-42	130 Flush	2022-11-19 11:25	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:06	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	Sample Date	Sample Description	Sample Matrix	Analysis Start Date/Time	Analyst Initials
132629-43	2022-11-19 11:26	131 Initial	Drinking Water		
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time
Metals - Total in Water by ICP-MS					
Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06 FR
<hr/>					
Reference Number	Sample Date	Sample Description	Sample Matrix	Analysis Start Date/Time	Analyst Initials
132629-44	2022-11-19 11:27	131 Flush	Drinking Water		
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time
Metals - Total in Water by ICP-MS					
Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06 FR
<hr/>					
Reference Number	Sample Date	Sample Description	Sample Matrix	Analysis Start Date/Time	Analyst Initials
132629-45	2022-11-19 11:27	132 Initial	Drinking Water		
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time
Metals - Total in Water by ICP-MS					
Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06 FR
<hr/>					
Reference Number	Sample Date	Sample Description	Sample Matrix	Analysis Start Date/Time	Analyst Initials
132629-46	2022-11-19 11:29	132 Flush	Drinking Water		
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time
Metals - Total in Water by ICP-MS					
Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06 FR
<hr/>					
Reference Number	Sample Date	Sample Description	Sample Matrix	Analysis Start Date/Time	Analyst Initials
132629-47	2022-11-19 11:29	133 Initial	Drinking Water		
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time
Metals - Total in Water by ICP-MS					
Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06 FR
<hr/>					
Reference Number	Sample Date	Sample Description	Sample Matrix	Analysis Start Date/Time	Analyst Initials
132629-48	2022-11-19 11:30	133 Flush	Drinking Water		
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time
Metals - Total in Water by ICP-MS					
Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06 FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	Sample Date	Sample Description	Sample Matrix	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
132629-49	2022-11-19 11:30	134 Initial	Drinking Water					
Analyte								
Metals - Total in Water by ICP-MS								
Lead		Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR
132629-50	2022-11-19 11:31	135 Initial	Drinking Water					
Analyte								
Metals - Total in Water by ICP-MS								
Lead		Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR
132629-51	2022-11-19 11:32	136 Initial	Drinking Water					
Analyte								
Metals - Total in Water by ICP-MS								
Lead		Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR
132629-52	2022-11-19 11:33	137 Initial	Drinking Water					
Analyte								
Metals - Total in Water by ICP-MS								
Lead		Total	0.6	µg/L	1	0.2	Dec 07, 2022 12:06	FR
132629-53	2022-11-19 11:35	139 Initial	Drinking Water					
Analyte								
Metals - Total in Water by ICP-MS								
Lead		Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR
132629-54	2022-11-19 11:35	139 Flush	Drinking Water					
Analyte								
Metals - Total in Water by ICP-MS								
Lead		Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	Sample Date	Sample Description	Sample Matrix	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
132629-55	2022-11-19 11:37	140 Initial	Drinking Water					
Analyte								
Metals - Total in Water by ICP-MS								
Lead		Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR
<hr/>								
132629-56	2022-11-19 11:40	141 Initial	Drinking Water					
Analyte								
Metals - Total in Water by ICP-MS								
Lead		Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR
<hr/>								
132629-57	2022-11-19 11:40	141 Flush	Drinking Water					
Analyte								
Metals - Total in Water by ICP-MS								
Lead		Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR
<hr/>								
132629-58	2022-11-19 11:43	143 Initial	Drinking Water					
Analyte								
Metals - Total in Water by ICP-MS								
Lead		Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR
<hr/>								
132629-59	2022-11-19 11:44	144 Initial	Drinking Water					
Analyte								
Metals - Total in Water by ICP-MS								
Lead		Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR
<hr/>								
132629-60	2022-11-19 11:46	144 Flush	Drinking Water					
Analyte								
Metals - Total in Water by ICP-MS								
Lead		Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	132629-61	Sample Date	2022-11-19 11:48			
Sample Description	145 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06 FR

Reference Number	132629-62	Sample Date	2022-11-19 11:49			
Sample Description	146 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06 FR

Reference Number	132629-63	Sample Date	2022-11-19 11:49			
Sample Description	146 Flush	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:06 FR

Reference Number	132629-64	Sample Date	2022-11-19 11:50			
Sample Description	147 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Reference Number	132629-65	Sample Date	2022-11-19 11:51			
Sample Description	148 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Reference Number	132629-66	Sample Date	2022-11-19 11:51			
Sample Description	148 Flush	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix	Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
132629-67	149 Initial	2022-11-19 11:54	Drinking Water	Metals - Total in Water by ICP-MS						
	Total			Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08	FR
132629-68	150 Initial	2022-11-19 11:54	Drinking Water	Metals - Total in Water by ICP-MS						
	Total			Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08	FR
132629-69	150 Flush	2022-11-19 11:55	Drinking Water	Metals - Total in Water by ICP-MS						
	Total			Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08	FR
132629-70	151 Initial	2022-11-19 11:57	Drinking Water	Metals - Total in Water by ICP-MS						
	Total			Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08	FR
132629-71	151 Flush	2022-11-19 11:59	Drinking Water	Metals - Total in Water by ICP-MS						
	Total			Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08	FR
132629-72	152 Initial	2022-11-19 11:59	Drinking Water	Metals - Total in Water by ICP-MS						
	Total			Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	132629-73	Sample Date	2022-11-19 12:00			
Sample Description	153 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Reference Number	132629-74	Sample Date	2022-11-19 12:01			
Sample Description	154 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Reference Number	132629-75	Sample Date	2022-11-19 12:02			
Sample Description	155 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Reference Number	132629-76	Sample Date	2022-11-19 12:03			
Sample Description	155 Flush	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Reference Number	132629-77	Sample Date	2022-11-19 12:03			
Sample Description	156 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Reference Number	132629-78	Sample Date	2022-11-19 12:05			
Sample Description	157 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-79	158 Initial	2022-11-19 12:06	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:08	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-80	158 Flush	2022-11-19 12:07	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:08	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-81	159 Initial	2022-11-19 12:08	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:08	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-82	160 Initial	2022-11-19 12:10	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:08	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-83	160 Flush	2022-11-19 12:11	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:08	FR
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-84	161 Initial	2022-11-19 12:12	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:08	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	Sample Date	Sample Description	Sample Matrix	Analysis Start Date/Time	Analyst Initials
132629-85	2022-11-19 12:14	162 Initial	Drinking Water		
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time
Metals - Total in Water by ICP-MS					
Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR
<hr/>					
Reference Number	Sample Date	Sample Description	Sample Matrix	Analysis Start Date/Time	Analyst Initials
132629-86	2022-11-19 12:14	163 Initial	Drinking Water		
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time
Metals - Total in Water by ICP-MS					
Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR
<hr/>					
Reference Number	Sample Date	Sample Description	Sample Matrix	Analysis Start Date/Time	Analyst Initials
132629-87	2022-11-19 12:15	164 Initial	Drinking Water		
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time
Metals - Total in Water by ICP-MS					
Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR
<hr/>					
Reference Number	Sample Date	Sample Description	Sample Matrix	Analysis Start Date/Time	Analyst Initials
132629-88	2022-11-19 12:15	165 Initial	Drinking Water		
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time
Metals - Total in Water by ICP-MS					
Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR
<hr/>					
Reference Number	Sample Date	Sample Description	Sample Matrix	Analysis Start Date/Time	Analyst Initials
132629-89	2022-11-19 12:18	166 Initial	Drinking Water		
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time
Metals - Total in Water by ICP-MS					
Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR
<hr/>					
Reference Number	Sample Date	Sample Description	Sample Matrix	Analysis Start Date/Time	Analyst Initials
132629-90	2022-11-19 12:19	166 Flush	Drinking Water		
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time
Metals - Total in Water by ICP-MS					
Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	Sample Date	Sample Description	Sample Matrix	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
132629-91	2022-11-19 12:19	167 Initial	Drinking Water					
Analyte								
Metals - Total in Water by ICP-MS								
Lead		Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08	FR
132629-92	2022-11-19 12:20	168 Initial	Drinking Water					
Analyte								
Metals - Total in Water by ICP-MS								
Lead		Total	1.5	µg/L	1	0.2	Dec 07, 2022 12:08	FR
132629-93	2022-11-19 12:22	169 Initial	Drinking Water					
Analyte								
Metals - Total in Water by ICP-MS								
Lead		Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08	FR
132629-94	2022-11-19 12:22	169 Flush	Drinking Water					
Analyte								
Metals - Total in Water by ICP-MS								
Lead		Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08	FR
132629-95	2022-11-19 12:23	170 Initial	Drinking Water					
Analyte								
Metals - Total in Water by ICP-MS								
Lead		Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08	FR
132629-96	2022-11-19 12:30	171 Initial	Drinking Water					
Analyte								
Metals - Total in Water by ICP-MS								
Lead		Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	132629-97	Sample Date	2022-11-19 12:30			
Sample Description	171 Flush	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Reference Number	132629-98	Sample Date	2022-11-19 12:33			
Sample Description	172 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Reference Number	132629-99	Sample Date	2022-11-19 12:33			
Sample Description	172 Flush	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Reference Number	132629-100	Sample Date	2022-11-19 12:34			
Sample Description	173 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Reference Number	132629-101	Sample Date	2022-11-19 12:35			
Sample Description	173 Flush	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Reference Number	132629-102	Sample Date	2022-11-19 12:35			
Sample Description	174 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	132629-103	Sample Date	2022-11-19 12:36			
Sample Description	174 Flush	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Reference Number	132629-104	Sample Date	2022-11-19 12:36			
Sample Description	175 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Reference Number	132629-105	Sample Date	2022-11-19 12:37			
Sample Description	175 Flush	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Reference Number	132629-106	Sample Date	2022-11-19 12:38			
Sample Description	176 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Reference Number	132629-107	Sample Date	2022-11-19 12:39			
Sample Description	177 Initial	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Reference Number	132629-108	Sample Date	2022-11-19 12:40			
Sample Description	177 Flush	Sample Matrix	Drinking Water			
Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
132629-109	178 Initial	2022-11-19 12:41	Drinking Water					
Analyte	Result	Units	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2		Dec 07, 2022 12:08	FR
132629-110	178 Flush	2022-11-19 12:41	Drinking Water					
132629-111	179 Initial	2022-11-19 12:42	Drinking Water					
132629-112	179 Flush	2022-11-19 12:43	Drinking Water					
132629-113	180 Initial	2022-11-19 12:44	Drinking Water					
132629-114	181 Initial	2022-11-19 12:45	Drinking Water					

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix	Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
132629-115	182 Initial	2022-11-19 12:45	Drinking Water	Metals - Total in Water by ICP-MS						
	Total			Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08	FR
132629-116	183 Initial	2022-11-19 12:47	Drinking Water	Metals - Total in Water by ICP-MS						
	Total			Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08	FR
132629-117	184 Initial	2022-11-19 12:47	Drinking Water	Metals - Total in Water by ICP-MS						
	Total			Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08	FR
132629-118	185 Initial	2022-11-19 12:48	Drinking Water	Metals - Total in Water by ICP-MS						
	Total			Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08	FR
132629-119	185 Flush	2022-11-19 12:48	Drinking Water	Metals - Total in Water by ICP-MS						
	Total			Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08	FR
132629-120	186 Initial	2022-11-19 12:50	Drinking Water	Metals - Total in Water by ICP-MS						
	Total			Lead	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Reference Number 132629-121	Sample Date 2022-11-19 12:50
Sample Description 186 Flush	Sample Matrix Drinking Water

Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Reference Number 132629-122	Sample Date 2022-11-19 12:52
Sample Description 187 Initial	Sample Matrix Drinking Water

Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Reference Number 132629-123	Sample Date 2022-11-19 12:53
Sample Description 188 Initial	Sample Matrix Drinking Water

Analyte	Result	Units	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS						
Lead	Total	<0.2	µg/L	1	0.2	Dec 07, 2022 12:08 FR

Approved by: 
 Megan Krauskopf
 Project Manager

Methodology and Notes

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1943: Slate Run Elementary School	Lot ID: 132629
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Nov 23, 2022
Company:	LSD:	Date Reported: Dec 9, 2022
	P.O.: IFA_LIF_2019	Report Number: 233268
	Proj. Acct. code:	

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Metals ICP-MS Total in water	EPA	Trace Elements in Waters and Wastes by Inductively Coupled Plasma-Mass Spectrometry, E200.8	Dec 7, 2022	Fort Wayne
Metals ICP-MS Total in water	EPA	Trace Elements in Waters and Wastes by Inductively Coupled Plasma-Mass Spectrometry, E200.8	Dec 7, 2022	Fort Wayne

References

EPA United States Environmental Protection Agency

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.