



Element
Suite 100, 328 Ley Road
Fort Wayne, Indiana
46825, United States

T: +1 (260) 471-7000
F: +1
E: Info.FortWayne@element.com
W: www.element.com

March 3, 2023

Aija Putelis
120 Water Audit
PO Box 604
ZIONSVILLE, IN 46077

RE: 1949: Fairmont Elementary

Dear Aija Putelis:

Lot Id: 140719

Element Materials Technology – Fort Wayne received 117 sample(s) on 2/16/2023 for the analyses presented in the following report.

In accordance with your instructions, a laboratory of Element Materials Technology Fort Wayne LLC either conducted or subcontracted these analyses. Subcontracted analyses will be identified in an accompanying case narrative and any associated report(s) will be attached in full. Unless otherwise noted in the case narrative, all analyses were conducted using approved methodologies. Reported results relate only to the items tested.

Estimated uncertainty is available upon request. This report shall not be reproduced, except in full, without the written approval of the laboratory.

If you have any questions regarding these test results, please feel free to call.

Sincerely,

Megan Krauskopf
Project Manager
Suite 100, 328 Ley Road,
Fort Wayne, IN 46825

Accreditation

TNI:2016 (Florida)
ISO 17025:2017 (A2LA)
Indiana - Fort Wayne
Indiana - Columbus
Indiana - South Bend
Michigan
South Dakota
Tennessee

Cert #

E871168
6190.02
M-02-05
M-03-02
M-71-02
9030
--
04911

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
140719-1	101 Initial	2023-02-11 07:30	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	0.4	µg/L	1	0.2			Mar 02, 2023 07:34	FR

Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
140719-2	101 Flush	2023-02-11 07:30	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	0.5	µg/L	1	0.2			Mar 02, 2023 07:34	FR

Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
140719-3	102 Initial	2023-02-11 07:33	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	0.4	µg/L	1	0.2			Mar 02, 2023 07:34	FR

Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
140719-4	102 Flush	2023-02-11 07:34	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	<0.2	µg/L	1	0.2			Mar 02, 2023 07:34	FR

Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
140719-5	103 Initial	2023-02-11 07:35	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	1.2	µg/L	1	0.2			Mar 02, 2023 07:34	FR

Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
140719-6	103a Initial	2023-02-11 07:35	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	0.3	µg/L	1	0.2			Mar 02, 2023 07:34	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
140719-7	103a Flush	2023-02-11 07:36	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	<0.2	µg/L			1	0.2	Mar 02, 2023 07:34	FR
140719-8	104 Initial	2023-02-11 07:38	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	0.4	µg/L			1	0.2	Mar 02, 2023 07:34	FR
140719-9	104 Flush	2023-02-11 07:38	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	0.2	µg/L			1	0.2	Mar 02, 2023 07:34	FR
140719-10	105 Initial	2023-02-11 07:39	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	0.3	µg/L			1	0.2	Mar 02, 2023 07:34	FR
140719-11	105a Initial	2023-02-11 07:40	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	<0.2	µg/L			1	0.2	Mar 02, 2023 07:34	FR
140719-12	105a Flush	2023-02-11 07:40	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	<0.2	µg/L			1	0.2	Mar 02, 2023 07:34	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
140719-13	106 Initial	2023-02-11 07:43	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	0.9	µg/L			1	0.2	Mar 02, 2023 07:34	FR
140719-14	107 Initial	2023-02-11 07:44	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	2.2	µg/L			1	0.2	Mar 02, 2023 07:34	FR
140719-15	107a Initial	2023-02-11 07:45	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	0.5	µg/L			1	0.2	Mar 02, 2023 07:34	FR
140719-16	107a Flush	2023-02-11 07:45	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	0.3	µg/L			1	0.2	Mar 02, 2023 07:34	FR
140719-17	108 Initial	2023-02-11 07:46	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	1.7	µg/L			1	0.2	Mar 02, 2023 07:34	FR
140719-18	109 Initial	2023-02-11 07:46	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	2.2	µg/L			1	0.2	Mar 02, 2023 07:34	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-19	110 Initial	2023-02-11 07:47	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.7	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-20	111 Initial	2023-02-11 07:48	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.4	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-21	112 Initial	2023-02-11 07:48	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-22	113 Initial	2023-02-11 07:49	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.8	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-23	114 Initial	2023-02-11 07:50	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.4	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-24	115 Initial	2023-02-11 07:51	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.1	µg/L	1	0.2	Mar 02, 2023 07:34	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-25	115a Initial	2023-02-11 07:51	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.3	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-26	115a Flush	2023-02-11 07:52	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.3	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-27	116 Initial	2023-02-11 07:54	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.3	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-28	117 Initial	2023-02-11 07:55	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.2	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-29	117a Initial	2023-02-11 07:56	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.2	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-30	117a Flush	2023-02-11 07:57	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:34	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
140719-31	118 Initial	2023-02-11 07:59	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	1.1	µg/L			1	0.2	Mar 02, 2023 07:34	FR
140719-32	119 Initial	2023-02-11 08:00	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	1.6	µg/L			1	0.2	Mar 02, 2023 07:34	FR
140719-33	119a Initial	2023-02-11 08:00	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	0.2	µg/L			1	0.2	Mar 02, 2023 07:34	FR
140719-34	119a Flush	2023-02-11 08:01	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	1.8	µg/L			1	0.2	Mar 02, 2023 07:34	FR
140719-35	120 Initial	2023-02-11 08:02	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	1.4	µg/L			1	0.2	Mar 02, 2023 07:34	FR
140719-36	121 Initial	2023-02-11 08:03	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	2.1	µg/L			1	0.2	Mar 02, 2023 07:34	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix	Analysis Start Date/Time	Analyst Initials		
140719-37	121a Initial	2023-02-11 08:03	Drinking Water				
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	0.3	µg/L	1	0.2	Mar 02, 2023 07:34	FR
Reference Number	Sample Description	Sample Date	Sample Matrix	Analysis Start Date/Time	Analyst Initials		
140719-38	121a Flush	2023-02-11 08:04	Drinking Water				
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:34	FR
Reference Number	Sample Description	Sample Date	Sample Matrix	Analysis Start Date/Time	Analyst Initials		
140719-39	122 Initial	2023-02-11 08:05	Drinking Water				
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	0.7	µg/L	1	0.2	Mar 02, 2023 07:34	FR
Reference Number	Sample Description	Sample Date	Sample Matrix	Analysis Start Date/Time	Analyst Initials		
140719-40	123 Initial	2023-02-11 08:05	Drinking Water				
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	2.4	µg/L	1	0.2	Mar 02, 2023 07:34	FR
Reference Number	Sample Description	Sample Date	Sample Matrix	Analysis Start Date/Time	Analyst Initials		
140719-41	123a Initial	2023-02-11 08:08	Drinking Water				
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	0.3	µg/L	1	0.2	Mar 02, 2023 07:34	FR
Reference Number	Sample Description	Sample Date	Sample Matrix	Analysis Start Date/Time	Analyst Initials		
140719-42	123a Flush	2023-02-11 08:08	Drinking Water				
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:34	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-43	124 Initial	2023-02-11 08:09	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.9	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-44	125 Initial	2023-02-11 08:10	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.3	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-45	125a Initial	2023-02-11 08:11	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.4	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-46	125a Flush	2023-02-11 08:12	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-47	126 Initial	2023-02-11 08:18	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	5.8	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-48	127 Initial	2023-02-11 08:19	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	3.6	µg/L	1	0.2	Mar 02, 2023 07:34	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-49	128 Initial	2023-02-11 08:22	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	3.0	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-50	128 Flush	2023-02-11 08:23	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.5	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-51	129 Initial	2023-02-11 08:24	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-52	129 Flush	2023-02-11 08:24	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-53	130 Initial	2023-02-11 08:26	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.4	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-54	130 Flush	2023-02-11 08:27	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.1	µg/L	1	0.2	Mar 02, 2023 07:34	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-55	131 Initial	2023-02-11 08:28	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.3	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-56	132 Initial	2023-02-11 08:29	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-57	133 Initial	2023-02-11 08:29	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-58	133 Flush	2023-02-11 08:30	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-59	134 Initial	2023-02-11 08:31	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.2	µg/L	1	0.2	Mar 02, 2023 07:34	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-60	134 Flush	2023-02-11 08:32	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:34	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-61	135 Initial	2023-02-11 08:33	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	3.8	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-62	136 Initial	2023-02-11 08:33	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.4	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-63	137 Initial	2023-02-11 08:34	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-64	138 Initial	2023-02-11 08:34	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.8	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-65	139 Initial	2023-02-11 08:35	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.7	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-66	140 Initial	2023-02-11 08:35	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
140719-67	141 Initial	2023-02-11 08:36	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	<0.2	µg/L			1	0.2	Mar 02, 2023 07:35	FR
140719-68	142 Initial	2023-02-11 08:37	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	0.2	µg/L			1	0.2	Mar 02, 2023 07:35	FR
140719-69	143 Initial	2023-02-11 08:38	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	<0.2	µg/L			1	0.2	Mar 02, 2023 07:35	FR
140719-70	143 Flush	2023-02-11 08:38	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	<0.2	µg/L			1	0.2	Mar 02, 2023 07:35	FR
140719-71	144 Initial	2023-02-11 08:40	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	0.5	µg/L			1	0.2	Mar 02, 2023 07:35	FR
140719-72	144 Flush	2023-02-11 08:40	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	<0.2	µg/L			1	0.2	Mar 02, 2023 07:35	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-73	145 Initial	2023-02-11 08:41	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-74	145 Flush	2023-02-11 08:42	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-75	146 Initial	2023-02-11 08:43	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-76	146 Flush	2023-02-11 08:43	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-77	147 Initial	2023-02-11 08:45	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-78	147 Flush	2023-02-11 08:45	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-79	148 Initial	2023-02-11 08:46	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-80	148 Flush	2023-02-11 08:47	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-81	149 Initial	2023-02-11 08:48	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-82	149 Flush	2023-02-11 08:49	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-83	150 Initial	2023-02-11 08:50	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-84	150 Flush	2023-02-11 08:50	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-85	151 Initial	2023-02-11 08:54	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-86	151 Flush	2023-02-11 08:54	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.3	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-87	152 Initial	2023-02-11 08:55	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-88	153 Initial	2023-02-11 08:57	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.3	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-89	154 Initial	2023-02-11 08:57	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.4	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-90	155 Initial	2023-02-11 08:58	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix	Analysis Start Date/Time	Analyst Initials		
140719-91	156 Initial	2023-02-11 08:58	Drinking Water				
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	1.5	µg/L	1	0.2	Mar 02, 2023 07:35	FR
Reference Number	Sample Description	Sample Date	Sample Matrix	Analysis Start Date/Time	Analyst Initials		
140719-92	157 Initial	2023-02-11 09:00	Drinking Water				
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	1.0	µg/L	1	0.2	Mar 02, 2023 07:35	FR
Reference Number	Sample Description	Sample Date	Sample Matrix	Analysis Start Date/Time	Analyst Initials		
140719-93	158 Initial	2023-02-11 09:00	Drinking Water				
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	2.1	µg/L	1	0.2	Mar 02, 2023 07:35	FR
Reference Number	Sample Description	Sample Date	Sample Matrix	Analysis Start Date/Time	Analyst Initials		
140719-94	159 Initial	2023-02-11 09:01	Drinking Water				
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	3.4	µg/L	1	0.2	Mar 02, 2023 07:35	FR
Reference Number	Sample Description	Sample Date	Sample Matrix	Analysis Start Date/Time	Analyst Initials		
140719-95	160 Initial	2023-02-11 09:01	Drinking Water				
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	2.0	µg/L	1	0.2	Mar 02, 2023 07:35	FR
Reference Number	Sample Description	Sample Date	Sample Matrix	Analysis Start Date/Time	Analyst Initials		
140719-96	161 Initial	2023-02-11 09:02	Drinking Water				
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	8.3	µg/L	1	0.2	Mar 02, 2023 07:35	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number	Sample Date	Sample Description	Sample Matrix	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
140719-97	2023-02-11 09:03	161 Flush	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.1	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
140719-98	2023-02-11 09:06	163 Initial	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.5	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
140719-99	2023-02-11 09:06	164 Initial	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.0	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
140719-100	2023-02-11 09:07	164 Flush	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.9	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
140719-101	2023-02-11 09:08	165 Initial	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
140719-102	2023-02-11 09:09	166 Initial	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.7	µg/L	1	0.2	Mar 02, 2023 07:35	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-103	167 Initial	2023-02-11 09:10	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.8	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-104	167 Flush	2023-02-11 09:10	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-105	168 Initial	2023-02-11 09:11	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.1	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-106	169 Initial	2023-02-11 09:11	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.0	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-107	169 Flush	2023-02-11 09:12	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.3	µg/L	1	0.2	Mar 02, 2023 07:35	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
140719-108	170 Initial	2023-02-11 09:15	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
140719-109	170 Flush	2023-02-11 09:15	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	<0.2	µg/L			1	0.2	Mar 02, 2023 07:35	FR
140719-110	171 Initial	2023-02-11 09:17	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	<0.2	µg/L			1	0.2	Mar 02, 2023 07:35	FR
140719-111	172 Initial	2023-02-11 09:20	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	1.2	µg/L			1	0.2	Mar 02, 2023 07:35	FR
140719-112	173 Initial	2023-02-11 09:22	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	<0.2	µg/L			1	0.2	Mar 02, 2023 07:35	FR
140719-113	173 Flush	2023-02-11 09:22	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	<0.2	µg/L			1	0.2	Mar 02, 2023 07:35	FR
140719-114	174 Initial	2023-02-11 09:23	Drinking Water						
Analyte									
Metals - Total in Water by ICP-MS									
Lead	Total	3.2	µg/L			1	0.2	Mar 02, 2023 07:35	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Reference Number 140719-115	Sample Date 2023-02-11 09:24
Sample Description 175 Initial	Sample Matrix Drinking Water

Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	1.3	µg/L	1	0.2	Mar 02, 2023 07:35	FR

Reference Number 140719-116	Sample Date 2023-02-11 09:25
Sample Description 176 Initial	Sample Matrix Drinking Water

Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	0.3	µg/L	1	0.2	Mar 02, 2023 07:35	FR

Reference Number 140719-117	Sample Date 2023-02-11 09:26
Sample Description 176 Flush	Sample Matrix Drinking Water

Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	<0.2	µg/L	1	0.2	Mar 02, 2023 07:35	FR

Approved by: 
Megan Krauskopf
Project Manager

Methodology and Notes

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1949: Fairmont Elementary	Lot ID: 140719
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By: JH	Project Location:	Date Received: Feb 16, 2023
Company:	LSD:	Date Reported: Mar 3, 2023
	P.O.: IFA_LIF_2019	Report Number: 241496
	Proj. Acct. code:	

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Metals ICP-MS Total in water	EPA	Trace Elements in Waters and Wastes by Inductively Coupled Plasma-Mass Spectrometry, E200.8	Mar 2, 2023	Fort Wayne
Metals ICP-MS Total in water	EPA	Trace Elements in Waters and Wastes by Inductively Coupled Plasma-Mass Spectrometry, E200.8	Mar 2, 2023	Fort Wayne

References

EPA United States Environmental Protection Agency

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.