

Remediation Plan

School: Grant Line Elementary

At Grant Line Elementary, a total number of 85 fixtures were tested. Two fixtures did present lead levels that exceed the EPA's action level. The action level of 15 ppb is not a measure of health effects. It serves as a signal to the facility to take steps to reduce lead in the water.

We have taken one or more of the following actions to address this situation:

- Shut off the water to these fixtures;
- Installed signs where applicable indicating these fixtures are for hand-washing only;
- Replaced the fixtures.

The following actions were taken for each fixture (in chronological order):

- **Fixture 120**
 - The fixture was taken offline on 1/5/2023.
 - The fixture was replaced on 1/13/2023.
 - The new fixture was retested on 3/17/2023.
 - The N.A.F.C.S. Corporation received the results on 3/28/2023. The samples tested were non-detect and the resumption of this fixture may go into effect immediately.

- **Fixture 127**
 - The fixture was taken offline on 1/5/2023.
 - The fixture was removed completely on 1/13/2023 (will never be used again).