



Element
Suite 100, 328 Ley Road
Fort Wayne, Indiana
46825, United States

T: +1 (260) 471-7000
F: +1
E: Info.FortWayne@element.com
W: www.element.com

August 11, 2023

Aija Putelis
120 Water Audit
PO Box 604
ZIONSVILLE, IN 46077

RE: 1931: Highland Hills Middle School

Dear Aija Putelis:

Lot Id: 158065

Element Materials Technology – Fort Wayne received 216 sample(s) on 7/31/2023 for the analyses presented in the following report.

In accordance with your instructions, a laboratory of Element Materials Technology Fort Wayne LLC either conducted or subcontracted these analyses. Subcontracted analyses will be identified in an accompanying case narrative and any associated report(s) will be attached in full. Unless otherwise noted in the case narrative, all analyses were conducted using approved methodologies. Reported results relate only to the items tested.

Estimated uncertainty is available upon request. This report shall not be reproduced, except in full, without the written approval of the laboratory.

If you have any questions regarding these test results, please feel free to call.

Sincerely,

Megan Krauskopf
Project Manager
Suite 100, 328 Ley Road,
Fort Wayne, IN 46825

Accreditation

TNI:2016 (Florida)
ISO 17025:2017 (A2LA)
Indiana – Fort Wayne
Indiana – Fort Wayne
Indiana – Columbus
Indiana – South Bend

Cert #

E871168
6190.02
C-02-03
M-02-05
M-03-02
M-71-02

Accreditation

Louisiana
Michigan
South Dakota
Tennessee

Cert #

235913
9030
--
04911

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
158065-1	101 Initial	2023-07-27 09:23	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	0.20	µg/L	1	0.20			Aug 09, 2023 08:07	FR

Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
158065-2	102 Initial	2023-07-27 09:23	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	0.51	µg/L	1	0.20			Aug 09, 2023 08:07	FR

Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
158065-3	102 Flush	2023-07-27 09:24	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	0.22	µg/L	1	0.20			Aug 09, 2023 08:07	FR

Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
158065-4	103 Initial	2023-07-27 09:24	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	<0.20	µg/L	1	0.20			Aug 09, 2023 08:07	FR

Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
158065-5	104 Initial	2023-07-27 09:25	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	<0.20	µg/L	1	0.20			Aug 09, 2023 08:07	FR

Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
158065-6	104 Flush	2023-07-27 09:26	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	<0.20	µg/L	1	0.20			Aug 09, 2023 08:07	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-7	105 Initial	2023-07-27 09:27	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.88	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
158065-8	106 Initial	2023-07-27 09:27	Drinking Water					
158065-8	106 Initial	2023-07-27 09:27	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.88	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
158065-9	107 Initial	2023-07-27 09:28	Drinking Water					
158065-9	107 Initial	2023-07-27 09:28	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.88	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
158065-10	108 Initial	2023-07-27 09:30	Drinking Water					
158065-10	108 Initial	2023-07-27 09:30	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
158065-11	111 Initial	2023-07-27 09:35	Drinking Water					
158065-11	111 Initial	2023-07-27 09:35	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.28	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
158065-12	111 Flush	2023-07-27 09:35	Drinking Water					
158065-12	111 Flush	2023-07-27 09:35	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.59	µg/L	1	0.20	Aug 09, 2023 08:07	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-13	112 Initial	2023-07-27 09:36	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.71	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
158065-14	113 Initial	2023-07-27 09:37	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.92	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
158065-15	113 Flush	2023-07-27 09:38	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.92	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
158065-16	114 Initial	2023-07-27 09:38	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.28	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
158065-17	115 Initial	2023-07-27 09:39	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.55	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
158065-18	116 Initial	2023-07-27 09:39	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	11.2	µg/L	1	0.20	Aug 09, 2023 08:07	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-19	117 Initial	2023-07-27 09:41	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.12	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-20	118 Initial	2023-07-27 09:42	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.70	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-21	119 Initial	2023-07-27 09:43	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.88	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-22	120 Initial	2023-07-27 09:43	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.35	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-23	124 Initial	2023-07-27 09:44	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.24	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-24	125 Initial	2023-07-27 09:46	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.38	µg/L	1	0.20	Aug 09, 2023 08:07	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-25	125 Flush	2023-07-27 09:46	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.26	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-26	126 Initial	2023-07-27 09:47	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.61	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-27	127 Initial	2023-07-27 09:48	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.56	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-28	129 Initial	2023-07-27 09:50	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.66	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-29	130 Initial	2023-07-27 09:51	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.75	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-30	131 Initial	2023-07-27 09:55	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.37	µg/L	1	0.20	Aug 09, 2023 08:07	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-31	131 Flush	2023-07-27 09:56	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.34	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-32	133 Initial	2023-07-27 09:57	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.58	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-33	134 Initial	2023-07-27 09:58	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.62	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-34	137 Initial	2023-07-27 10:03	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.05	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-35	137 Flush	2023-07-27 10:03	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.99	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-36	138 Initial	2023-07-27 10:04	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.42	µg/L	1	0.20	Aug 09, 2023 08:07	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix	Analysis Start Date/Time	Analyst Initials		
158065-37	139 Initial	2023-07-27 10:05	Drinking Water				
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	3.44	µg/L	1	0.20	Aug 09, 2023 08:07	FR
Reference Number	Sample Description	Sample Date	Sample Matrix	Analysis Start Date/Time	Analyst Initials		
158065-38	140 Initial	2023-07-27 10:10	Drinking Water				
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	<0.20	µg/L	1	0.20	Aug 09, 2023 08:07	FR
Reference Number	Sample Description	Sample Date	Sample Matrix	Analysis Start Date/Time	Analyst Initials		
158065-39	140 Flush	2023-07-27 10:11	Drinking Water				
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	<0.20	µg/L	1	0.20	Aug 09, 2023 08:07	FR
Reference Number	Sample Description	Sample Date	Sample Matrix	Analysis Start Date/Time	Analyst Initials		
158065-40	144 Initial	2023-07-27 11:59	Drinking Water				
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	1.04	µg/L	1	0.20	Aug 09, 2023 08:07	FR
Reference Number	Sample Description	Sample Date	Sample Matrix	Analysis Start Date/Time	Analyst Initials		
158065-41	145 Initial	2023-07-27 11:59	Drinking Water				
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	1.04	µg/L	1	0.20	Aug 09, 2023 08:07	FR
Reference Number	Sample Description	Sample Date	Sample Matrix	Analysis Start Date/Time	Analyst Initials		
158065-42	146 Initial	2023-07-27 12:00	Drinking Water				
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	1.20	µg/L	1	0.20	Aug 09, 2023 08:07	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-43	147 Initial	2023-07-27 12:00	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.93	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-44	150 Initial	2023-07-27 12:01	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.65	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-45	150 Flush	2023-07-27 12:04	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.53	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-46	152 Initial	2023-07-27 12:07	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.58	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-47	152 Flush	2023-07-27 12:07	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-48	153 Initial	2023-07-27 12:08	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.89	µg/L	1	0.20	Aug 09, 2023 08:07	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-49	154 Initial	2023-07-27 12:09	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.60		1	0.20	Aug 09, 2023 08:07	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-50	155 Initial	2023-07-27 12:10	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.96		1	0.20	Aug 09, 2023 08:07	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-51	155 Flush	2023-07-27 12:10	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20		1	0.20	Aug 09, 2023 08:07	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-52	156 Initial	2023-07-27 12:11	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.36		1	0.20	Aug 09, 2023 08:07	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-53	157 Initial	2023-07-27 12:12	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.83		1	0.20	Aug 09, 2023 08:07	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-54	158 Initial	2023-07-27 12:13	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.80		1	0.20	Aug 09, 2023 08:07	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-55	159 Initial	2023-07-27 12:14	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.41	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-56	159 Flush	2023-07-27 12:15	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.28	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-57	160 Initial	2023-07-27 12:15	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.01	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-58	161 Initial	2023-07-27 12:16	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.17	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-59	163 Initial	2023-07-27 12:18	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20	µg/L	1	0.20	Aug 09, 2023 08:07	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-60	163 Flush	2023-07-27 12:18	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20	µg/L	1	0.20	Aug 09, 2023 08:07	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-61	165 Initial	2023-07-27 12:21	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.74	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-62	166 Initial	2023-07-27 12:22	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.09	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-63	167 Initial	2023-07-27 12:40	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.05	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-64	168 Initial	2023-07-27 12:41	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.35	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-65	169 Initial	2023-07-27 12:42	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.52	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-66	169 Flush	2023-07-27 12:42	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.79	µg/L	1	0.20	Aug 09, 2023 08:08	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-67	170 Initial	2023-07-27 12:43	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.24	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-68	170 Flush	2023-07-27 12:44	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-69	171 Initial	2023-07-27 12:44	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-70	172 Initial	2023-07-27 12:46	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	11.0	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-71	172 Flush	2023-07-27 12:47	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.80	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-72	173 Initial	2023-07-27 12:48	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	27.0	µg/L	1	0.20	Aug 09, 2023 08:08	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-73	174 Initial	2023-07-27 12:49	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	4.96	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-74	174 Flush	2023-07-27 12:50	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.23	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-75	175 Initial	2023-07-27 12:50	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.32	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-76	176 Initial	2023-07-27 12:52	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-77	177 Initial	2023-07-27 12:54	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.58	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-78	177 Flush	2023-07-27 12:54	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20	µg/L	1	0.20	Aug 09, 2023 08:08	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-79	178 Initial	2023-07-27 12:55	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.69	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-80	179 Initial	2023-07-27 12:55	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.58	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-81	180 Initial	2023-07-27 12:56	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.36	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-82	180 Flush	2023-07-27 12:57	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.81	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-83	181 Initial	2023-07-27 13:03	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.84	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-84	182 Initial	2023-07-27 13:03	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.72	µg/L	1	0.20	Aug 09, 2023 08:08	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-85	183 Initial	2023-07-27 13:04	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.66	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-86	184 Initial	2023-07-27 13:04	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.56	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-87	185 Initial	2023-07-27 13:05	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.52	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-88	186 Initial	2023-07-27 13:05	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-89	187 Initial	2023-07-27 13:06	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.55	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-90	189 Initial	2023-07-27 13:07	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.66	µg/L	1	0.20	Aug 09, 2023 08:08	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-91	190 Initial	2023-07-27 13:07	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.45	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-92	191 Initial	2023-07-27 13:08	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.61	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-93	192 Initial	2023-07-27 13:08	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.63	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-94	193 Initial	2023-07-27 13:10	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.58	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-95	194 Initial	2023-07-27 13:10	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.68	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-96	195 Initial	2023-07-27 13:11	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.68	µg/L	1	0.20	Aug 09, 2023 08:08	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-97	196 Initial	2023-07-27 13:12	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.55	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-98	197 Initial	2023-07-27 13:12	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.26	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-99	199 Initial	2023-07-27 13:14	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.39	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-100	201 Initial	2023-07-27 13:15	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-101	202 Initial	2023-07-27 13:16	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-102	202 Flush	2023-07-27 13:16	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.46	µg/L	1	0.20	Aug 09, 2023 08:08	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-103	203 Initial	2023-07-27 13:17	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.39	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-104	204 Initial	2023-07-27 13:17	Drinking Water					
Metals - Total in Water by ICP-MS								
Lead	Total	0.31	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-105	205 Initial	2023-07-27 13:18	Drinking Water					
Metals - Total in Water by ICP-MS								
Lead	Total	0.32	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-106	206 Initial	2023-07-27 13:19	Drinking Water					
Metals - Total in Water by ICP-MS								
Lead	Total	0.30	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-107	207 Initial	2023-07-27 13:20	Drinking Water					
Metals - Total in Water by ICP-MS								
Lead	Total	0.27	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-108	208 Initial	2023-07-27 13:20	Drinking Water					
Metals - Total in Water by ICP-MS								
Lead	Total	0.30	µg/L	1	0.20	Aug 09, 2023 08:08	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-109	211 Initial	2023-07-27 13:23	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20		1	0.20	Aug 09, 2023 08:08	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-110	212 Initial	2023-07-27 13:37	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.36		1	0.20	Aug 09, 2023 08:08	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-111	212 Flush	2023-07-27 13:38	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.48		1	0.20	Aug 09, 2023 08:08	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-112	213 Initial	2023-07-27 13:38	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	6.62		1	0.20	Aug 09, 2023 08:08	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-113	214 Initial	2023-07-27 13:39	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	4.80		1	0.20	Aug 09, 2023 08:08	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-114	215 Initial	2023-07-27 13:40	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	7.65		1	0.20	Aug 09, 2023 08:08	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-115	216 Initial	2023-07-27 13:40	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	3.21	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-116	217 Initial	2023-07-27 13:41	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.51	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-117	217 Flush	2023-07-27 13:41	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-118	218 Initial	2023-07-27 13:43	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.96	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-119	220 Initial	2023-07-27 13:45	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.72	µg/L	1	0.20	Aug 09, 2023 08:08	FR	
158065-120	220 Flush	2023-07-27 13:45	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.32	µg/L	1	0.20	Aug 09, 2023 08:08	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-121	221 Initial	2023-07-27 13:48	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.90	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-122	223 Initial	2023-07-27 13:49	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.46	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-123	224 Initial	2023-07-27 13:49	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.10	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-124	228 Initial	2023-07-27 13:50	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-125	229 Initial	2023-07-27 13:51	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.45	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-126	230 Initial	2023-07-27 13:52	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.91	µg/L	1	0.20	Aug 09, 2023 08:09	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-127	231 Initial	2023-07-27 13:52	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.05	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-128	232 Initial	2023-07-27 13:53	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.68	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-129	235 Initial	2023-07-27 13:54	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	10.0	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-130	235 Flush	2023-07-27 13:54	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.45	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-131	236 Initial	2023-07-27 13:55	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	9.58	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-132	237 Initial	2023-07-27 13:55	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	5.30	µg/L	1	0.20	Aug 09, 2023 08:09	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number 158065-133	Sample Date 2023-07-27 13:57
Sample Description 238 Initial	Sample Matrix Drinking Water

Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	1.29	µg/L	1	0.20	Aug 09, 2023 08:09	FR

Reference Number 158065-134	Sample Date 2023-07-27 13:57
Sample Description 239 Initial	Sample Matrix Drinking Water

Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	4.84	µg/L	1	0.20	Aug 09, 2023 08:09	FR

Reference Number 158065-135	Sample Date 2023-07-27 13:58
Sample Description 239 Flush	Sample Matrix Drinking Water

Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	0.54	µg/L	1	0.20	Aug 09, 2023 08:09	FR

Reference Number 158065-136	Sample Date 2023-07-27 13:59
Sample Description 240 Initial	Sample Matrix Drinking Water

Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	5.14	µg/L	1	0.20	Aug 09, 2023 08:09	FR

Reference Number 158065-137	Sample Date 2023-07-27 13:59
Sample Description 241 Initial	Sample Matrix Drinking Water

Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	1.53	µg/L	1	0.20	Aug 09, 2023 08:09	FR

Reference Number 158065-138	Sample Date 2023-07-27 14:00
Sample Description 241 Flush	Sample Matrix Drinking Water

Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS							
Lead	Total	0.39	µg/L	1	0.20	Aug 09, 2023 08:09	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-139	242 Initial	2023-07-27 14:01	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.69	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-140	243 Initial	2023-07-27 14:01	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.29	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-141	243 Flush	2023-07-27 14:02	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-142	244 Initial	2023-07-27 14:03	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.08	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-143	245 Initial	2023-07-27 14:05	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.50	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-144	245 Flush	2023-07-27 14:06	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.35	µg/L	1	0.20	Aug 09, 2023 08:09	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-145	246 Initial	2023-07-27 14:08	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-146	246 Flush	2023-07-27 14:09	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-147	247 Initial	2023-07-27 14:10	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-148	248 Initial	2023-07-27 14:13	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.23	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-149	248 Flush	2023-07-27 14:13	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.36	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-150	249 Initial	2023-07-27 14:14	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.58	µg/L	1	0.20	Aug 09, 2023 08:09	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-151	250 Initial	2023-07-27 14:14	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	3.57	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-152	250 Flush	2023-07-27 14:15	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.50	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-153	251 Initial	2023-07-27 14:16	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.30	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-154	252 Initial	2023-07-27 14:16	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.82	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-155	253 Initial	2023-07-27 14:17	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.86	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-156	254 Initial	2023-07-27 14:17	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.90	µg/L	1	0.20	Aug 09, 2023 08:09	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-157	255 Initial	2023-07-27 14:18	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	3.76	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-158	256 Initial	2023-07-27 14:18	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	17.9	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-159	256 Flush	2023-07-27 14:19	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.83	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-160	257 Initial	2023-07-27 14:23	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.92	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-161	257 Flush	2023-07-27 14:23	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.66	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-162	258 Initial	2023-07-27 14:24	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.39	µg/L	1	0.20	Aug 09, 2023 08:09	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-163	259 Initial	2023-07-27 14:24	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	3.97	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-164	260 Initial	2023-07-27 14:24	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	3.58	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-165	261 Initial	2023-07-27 14:25	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.83	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-166	264 Initial	2023-07-27 14:26	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	11.9	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-167	265 Initial	2023-07-27 14:27	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	27.3	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-168	265 Flush	2023-07-27 14:27	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.69	µg/L	1	0.20	Aug 09, 2023 08:09	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-169	266 Initial	2023-07-27 14:30	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	3.51	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-170	267 Initial	2023-07-27 14:31	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	3.18	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-171	269 Initial	2023-07-27 14:31	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.54	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-172	269 Flush	2023-07-27 14:32	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.93	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-173	270 Initial	2023-07-27 14:33	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	9.09	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
158065-174	271 Initial	2023-07-27 14:33	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	5.18	µg/L	1	0.20	Aug 09, 2023 08:09	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-175	272 Initial	2023-07-27 14:34	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	3.03	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-176	273 Initial	2023-07-27 14:34	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.13	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-177	275 Initial	2023-07-27 14:35	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.38	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-178	276 Initial	2023-07-27 14:35	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.37	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-179	277 Initial	2023-07-27 14:35	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.20	µg/L	1	0.20	Aug 09, 2023 08:09	FR	
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-180	278 Initial	2023-07-27 14:36	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.67	µg/L	1	0.20	Aug 09, 2023 08:09	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-181	281 Initial	2023-07-27 14:37	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.48		1	0.20	Aug 09, 2023 08:10	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-182	282 Initial	2023-07-27 14:37	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	4.65		1	0.20	Aug 09, 2023 08:10	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-183	283 Initial	2023-07-27 14:37	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.07		1	0.20	Aug 09, 2023 08:10	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-184	284 Initial	2023-07-27 14:39	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	1.04		1	0.20	Aug 09, 2023 08:10	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-185	285 Initial	2023-07-27 14:40	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20		1	0.20	Aug 09, 2023 08:10	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-186	288 Initial	2023-07-27 14:41	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	9.62		1	0.20	Aug 09, 2023 08:10	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-187	288 Flush	2023-07-27 14:41	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.75	µg/L	1	0.20	Aug 09, 2023 08:10	FR	
158065-188	289 Initial	2023-07-27 14:42	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	7.23	µg/L	1	0.20	Aug 09, 2023 08:10	FR	
158065-189	290 Initial	2023-07-27 14:42	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	2.70	µg/L	1	0.20	Aug 09, 2023 08:10	FR	
158065-190	291 Initial	2023-07-27 14:43	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	8.26	µg/L	1	0.20	Aug 09, 2023 08:10	FR	
158065-191	292 Initial	2023-07-27 14:43	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	12.8	µg/L	1	0.20	Aug 09, 2023 08:10	FR	
158065-192	292 Flush	2023-07-27 14:44	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.45	µg/L	1	0.20	Aug 09, 2023 08:10	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
158065-193	293 Initial	2023-07-27 14:45	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	11.9	µg/L	1	0.20			Aug 09, 2023 08:10	FR
158065-194	294 Initial	2023-07-27 14:46	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	9.45	µg/L	1	0.20			Aug 09, 2023 08:10	FR
158065-195	295 Initial	2023-07-27 14:46	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	3.00	µg/L	1	0.20			Aug 09, 2023 08:10	FR
158065-196	295 Flush	2023-07-27 14:47	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	0.33	µg/L	1	0.20			Aug 09, 2023 08:10	FR
158065-197	296 Initial	2023-07-27 14:49	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	0.76	µg/L	1	0.20			Aug 09, 2023 08:10	FR
158065-198	297 Initial	2023-07-27 14:49	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	<0.20	µg/L	1	0.20			Aug 09, 2023 08:10	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
158065-199	297 Flush	2023-07-27 14:50	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	<0.20	µg/L	1	0.20			Aug 09, 2023 08:10	FR
Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
158065-200	298 Initial	2023-07-27 14:50	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	0.96	µg/L	1	0.20			Aug 09, 2023 08:10	FR
Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
158065-201	299 Initial	2023-07-27 14:51	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	<0.20	µg/L	1	0.20			Aug 09, 2023 08:10	FR
Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
158065-202	300 Initial	2023-07-27 14:52	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	0.61	µg/L	1	0.20			Aug 09, 2023 08:10	FR
Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
158065-203	300 Flush	2023-07-27 14:53	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	<0.20	µg/L	1	0.20			Aug 09, 2023 08:10	FR
Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
158065-204	301 Initial	2023-07-27 14:54	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	0.97	µg/L	1	0.20			Aug 09, 2023 08:10	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix					Analysis Start Date/Time	Analyst Initials
158065-205	302 Initial	2023-07-27 14:54	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	1.01	µg/L	1	0.20			Aug 09, 2023 08:10	FR
158065-206	303 Initial	2023-07-27 14:56	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	10.5	µg/L	1	0.20			Aug 09, 2023 08:10	FR
158065-207	304 Initial	2023-07-27 14:57	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	7.16	µg/L	1	0.20			Aug 09, 2023 08:10	FR
158065-208	305 Initial	2023-07-27 14:57	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	15.8	µg/L	1	0.20			Aug 09, 2023 08:10	FR
158065-209	305 Flush	2023-07-27 14:58	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	0.62	µg/L	1	0.20			Aug 09, 2023 08:10	FR
158065-210	306 Initial	2023-07-27 14:59	Drinking Water						
Analyte	Result	Units	Qal	DF	Nominal DL			Analysis Start Date/Time	Analyst Initials
Metals - Total in Water by ICP-MS									
Lead	Total	15.6	µg/L	1	0.20			Aug 09, 2023 08:10	FR

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-211	307 Initial	2023-07-27 14:59	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	<0.20		1	0.20	Aug 09, 2023 08:10	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-212	308 Initial	2023-07-27 15:00	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	14.9		1	0.20	Aug 09, 2023 08:10	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-213	309 Initial	2023-07-27 15:00	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	20.1		1	0.20	Aug 09, 2023 08:10	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-214	310 Initial	2023-07-27 15:01	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	8.18		1	0.20	Aug 09, 2023 08:10	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-215	311 Initial	2023-07-27 15:01	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	6.85		1	0.20	Aug 09, 2023 08:10	FR	
<hr/>								
Reference Number	Sample Description	Sample Date	Sample Matrix				Analysis Start Date/Time	Analyst Initials
158065-216	311 Flush	2023-07-27 15:02	Drinking Water					
Analyte	Result	Units	Qal	DF	Nominal DL	Analysis Start Date/Time	Analyst Initials	
Metals - Total in Water by ICP-MS								
Lead	Total	0.61		1	0.20	Aug 09, 2023 08:10	FR	

Analytical Report

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Approved by:



Megan Krauskopf
Project Manager

Data have been validated by Analytical Quality Control and Element's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To: 120 Water Audit PO Box 604 ZIONSVILLE, IN, United States 46077	Project ID: 1931: Highland Hills Middle School	Lot ID: 158065
Attn: Accounts Payable	Project Name:	Control Number:
Sampled By:	Project Location:	Date Received: Jul 31, 2023
Company:	LSD:	Date Reported: Aug 11, 2023
	P.O.: IFA_LIF_2019	Report Number: 258802
	Proj. Acct. code:	

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Metals ICP-MS Total in water	EPA	Trace Elements in Waters and Wastes by Inductively Coupled Plasma-Mass Spectrometry, E200.8	Aug 9, 2023	Fort Wayne
Metals ICP-MS Total in water	EPA	Trace Elements in Waters and Wastes by Inductively Coupled Plasma-Mass Spectrometry, E200.8	Aug 9, 2023	Fort Wayne
Metals ICP-MS Total in water	EPA	Trace Elements in Waters and Wastes by Inductively Coupled Plasma-Mass Spectrometry, E200.8	Aug 9, 2023	Fort Wayne
Metals ICP-MS Total in water	EPA	Trace Elements in Waters and Wastes by Inductively Coupled Plasma-Mass Spectrometry, E200.8	Aug 9, 2023	Fort Wayne

References

EPA United States Environmental Protection Agency

Please direct any inquiries regarding this report to our Client Services group.
Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.