

# Remediation Plan

**School: Hazelwood Middle School**

At Hazelwood Middle School, a total number of 167 fixtures were tested. 24 fixtures did present lead levels that exceed the EPA's action level. The action level of 15 ppb is not a measure of health effects. It serves as a signal to the facility to take steps to reduce lead in the water.

We have taken one or more of the following actions to address this situation:

- Shut off the water to these fixtures;
- Installed signs where applicable indicating these fixtures are for hand-washing only;
- Replaced the fixtures.

The following actions were taken for each fixture (in chronological order):

- **Fixtures 167 & 183**

- The fixture was taken offline on 8/8/2023.
- “Do Not Use” signs were posted on 8/8/2023.
- The fixture was replaced on 9/11/2023.
- The new fixture was retested on 9/19/2023.
- The N.A.F.C.S. Corporation received the results on 9/28/2023. The samples tested were non-detect and the resumption of this fixture may go into effect immediately.

- **Fixtures 205, 207, 212, 213, 230, 231, 232, 233, 234, 235, 236, 241, 242, 243, 244, 247, 249, 251, 252, 254, 259, & 263**

- The fixture was taken offline on 8/8/2023.
- “Do Not Use” signs were posted on 8/8/2023.
- The fixture was brought back online on 9/11/2023.
- Posted additional signage stating, “The sink water in this room is not for drinking” on 9/11/2023.