

# Remediation Plan

**School: New Albany High School**

At New Albany High School, a total number of 410 fixtures were tested. 40 fixtures did present lead levels that exceed the EPA's action level. The action level of 15 ppb is not a measure of health effects. It serves as a signal to the facility to take steps to reduce lead in the water.

We have taken one or more of the following actions to address this situation:

- Shut off the water to these fixtures;
- Installed signs where applicable indicating these fixtures are for hand-washing only;
- Replaced the fixtures.

The following actions were taken for each fixture (in chronological order):

- **Fixtures 451, 446B, 446A, 446, 445B, 445, 444B, 444, 433B, 433, 431B, 431, 430B, 430A, 430, 429B, 429A, 429, 428B, 428A, 428, 427B, 427A, 427, 418, 417, 416, 252, 202, 197, 196, 174, 165, 159, 155, 151, 147, 142, 134, & 125**
  - The fixture was taken offline on 4/18/2024.
  - “Do Not Use” signs were posted on 4/18/2024.
  - The fixture was brought back online on 4/29/2024.
  - Additional signage was posted stating, “The sink water in this room is NOT for drinking” on 4/29/2024.