

# Remediation Plan

**School: Floyd Central High School**

At Floyd Central High School, a total number of 249 fixtures were tested. 32 fixtures did present lead levels that exceed the EPA's action level. The action level of 15 ppb is not a measure of health effects. It serves as a signal to the facility to take steps to reduce lead in the water.

We have taken one or more of the following actions to address this situation:

- Shut off the water to these fixtures;
- Installed signs where applicable indicating these fixtures are for hand-washing only;
- Replaced the fixtures.

The following actions were taken for each fixture (in chronological order):

- **Fixtures 122, 184, 185, 186, 187, 194, 201, 205, 211, 212, 216, 219, 220, 225, 227, 228, 229, 242, 256, 268, 269, 271, 273, 288, 289, 294, 297, 298, 122, 184, 187, & 220**
  - The fixture was taken offline on 4/10/2024.
  - “Do Not Use” signs were posted on 4/10/2024.
  - The plan is to flush the fixture and then re-sample. The flush date is unknown; it depends on when new samples are received for testing.

More information will be presented after the re-sampling takes place.